

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

Memo No. 111

Dated: 12-07-2023

It is certified that an inspection team headed by Sri Jaglal Ram (Name of Officers with designation) from Junior Engineer (Name of Department/ Office) inspected the Public Health Section Manjha (Gopalganj) (Name & Address of the school) on 12.07.2023 (date of inspection) and found that the Gyanada International School Chhawahi Khas, Gopalganj (Bihar) (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/ U.T/. Govt.

The above is valid for a period of 12.07.2023 to 1 (one) Year

Signature with Seal:


Name :


Designation :


Name & Address of the Office / Department :

To

Gyanada International school
 Chhawahi khas, Gopalganj, Bihar

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, Translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

Government of Bihar
Public Health Engineering Department
Water Quality Test Report

District Name: Gopalganj

Division Name: P.H.Sub Division Barauli

SL. No.	Block	Panchayat	Village	T.S	Location of Source	Parameters														Date of sempaling	Date of Testing	Remarks
						pH	Turbidity (NTU)	EC	TDS (mg/l)	Total Hardness (mg/l)	Calcium (mg/l)	Magnesium (mg/l)	Chloride (mg/l)	Total Alkalinity (mg/l)	Iron (mg/l)	Nitrate (mg/l)	Sulphate (mg/l)	Fluoride (mg/l)	Total Coli			
1	Manjha	Chhawahikhas	Chhawahikhas	Govt H. P	Gyanda International school	7.81	X	525	341	200	88	15	20	460	0.08	0.28	X	0.16	ABSENT	05.06.2023	07.06.2023	Safe
Desirable Limit*						6.5-8.5	1.0	-	500	200	75	30	250	200	0.3	45	200	1.0	-			
Permissible Limit* in absence of alternate source (IS 10500:2012 - 2nd revision & Rev 2015)						NR	5.0	-	2000	600	200	100	1000	600	1.0	NR	400	1.5	**			

[Signature]
 8-6-2023
 Chemist
 SDL, P.H.Sub Division Barauli

[Signature]
 8-6-23
 JE
 P.H Sec. Manjha

[Signature]
 AE 8/6/23
 P.H.Sub Division Barauli

[Signature]
 Executive Engineer
 P.H.Division, Gopalganj