

**HIMACHAL PRADESH PUBLIC WORKS DEPARTMENT**  
**Office of the Assistant Engineer, HP, PWD, Sub-Division Kunihar**  
Web:-www.hppwd.gov.in Ph.No. 01796-262301

Dated:- 14/10/2024

No:- PW/ KSD/School Bldg/ 2024-25-

891

To

The Executive Engineer,  
Arki Division, HP.PWD.,  
Arki.

Subject:-

Application for renewal of building safety certificate regarding.

Sir,

Please refer to your office endorsement No. PW/AD/DB/Structure Stability/2024-5546 dated 05.10.2024 on the subject captioned above. In this context, it is informed that the building of The S.V.N. School, Kunihar at Badorighatti, Tehsil Arki, Distt. Solan HP has been inspected by Junior Engineer concerned alongwith Work Inspector on dated 14.10.2024 and reported that building is situated along SAKB road at RD 24/660 (valley side) which have 5 stories in One Block. The building appears visually safe for human habitation in normal condition and is safe for running the school. This is for your kind information and taking further necessary action please.

Encl:- School building file as received.



*Meer*  
Assistant Engineer,  
Kunihar Sub Division,  
H.P.P.W.D. Kunihar.  
*Meer*


FR



## SAFETY CERTIFICATE

The School building of The SVN School Kunihar at Badorighatti Tehsil- Arki , Distt- Solan, H.P. has been inspected by the Junior Engineer concerned section on dated 14.10.2024. As reported by Assistant Engineer Kunihar Sub Division vide letter no PW/KSD/School Bldg./2024-25-891 dated 14.10.2024 , it has been observed that no earth quake resistant Provisions have been adopted for this building and no Structure drawings apprpved by the Competent Govt. Certified Engineer have been produced at the time of inspection. Moreover no assistance was taken from PWD for constructing the building. This structure is a non- engineered structure. Hence the structural Safety of this building cannot be ensured specifically from earthquake resistance point of view. This department will not be held responsible for any type of loss of life and property etc. if this structure fails under any circumstances.

However as per visual inspection the building has been found safe at present and there is a five stories in one block only. No Officer/Official of this department will attend plea in any Hon'ble Court of law in case of any dispute. This certificate is valid from November 2024 to November 2029 . The building has been completed in the year 2018 . As per notification received from the Additional Chief Secretary (PW) to the Government of Himachal Pradesh vide letter No PBW (B) E (3) 95/2019 dated 05.05.2021.

  
Executive Engineer,  
Arki Divison, HP, PWD,  
Arki